

Mayor
Michael Morgan
Council
Harriet Prinz
Calvin Creech
Paul Ramirez
Jason Sheffler
Laurie Bailey



City Staff
City Administrator
Jeff Straub
Chief of Police
Gary O. Smith
Court Clerk
Sue Haire
Water Clerk
Jo Marie Johnson

201 East Main Street Troy, Texas 76579 | Main: 254.938-2505 | Fax: 254.938.0440

The Texas Commission on Environmental Quality (TCEQ) has notified the CITY OF TROY TX0140037 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for total trihalomethanes. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for total trihalomethanes to be 0.080 milligrams per liter (mg/L) based on locational running annual average (LRAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for total trihalomethanes indicates a compliance value in quarter three of 2016 of 0.108 mg/L for DBP2-01.

Trihalomethanes are a group of volatile organic compounds that are formed when chlorine, added to the water during the treatment process for disinfection, reacts with naturally-occurring organic matter in the water.

Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous systems, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

The City of Troy is in the process of securing funding for new water well. We will also continue to work with the City of Temple, our primary water supplier to remedy this issue. We will continue and increase its of flushing at dead end lines. We continue to research options for looping system distribution and Engineers are working on a new Well system to mix with existing water supply that also includes additional disinfection facilities.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Jeff Straub at 254-938-2505.

Posted/Delivered on:

12-30-16